## Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011.

Information to identify the model(s) to which the information relates to:

AIR CONDITIONER

TYPE : SINGLE SPLIT CASSETTE Indoor unit(s) : AUXG18KRLB Outdoor unit : AOYG18KATA BRAND : FUJITSU

N/A = Not Applicable

Function							
Cooling	Yes	Average	Yes				
Heating	Yes	Warmer	No				
		Colder	No				

Design load			Seasonal efficiency				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	5.2	kW	Cooling	SEER	6.20	-
Heating/Average	Pdesignh	3.8	kW	Heating/Average	SCOP/A	4.10	-
Heating/Warmer	Pdesignh	N/A	kW	Heating/Warmer	SCOP/W	N/A	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling							
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj			Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outo	loor temper	ature Tj		
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Tj = 35°C	Pdc	5.20	kW	Tj = 35°C	EER d	3.25	-
Tj = 30°C	Pdc	3.83	kW	Tj = 30°C	EER d	4.28	-
Tj = 25°C	Pdc	2.46	kW	Tj = 25°C	EER d	7.92	-
Tj = 20°C	Pdc	2.13	kW	Tj = 20°C	EER d	12.00	-

Heating/Average									
Declared capacity for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Average season, at indoor temperature 20 °C and outdoor temperature Tj					
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit		
Tj = -7°C	Pdh	3.36	kW	Tj = -7°C	COPd	2.64	-		
Tj = 2°C	Pdh	2.05	kW	Tj = 2°C	COPd	3.93	-		
Tj = 7°C	Pdh	1.32	kW	Tj = 7°C	COPd	5.56	-		
Tj = 12°C	Pdh	1.29	kW	Tj = 12°C	COPd	7.14	-		
Tj = bivalent temperature	Pdh	3.36	kW	Tj = bivalent temperature	COPd	2.64	-		
Tj = operating limit	Pdh	2.92	kW	Tj = operating limit	COPd	2.39	-		

Heating/Warmer									
Declared capacity for heating/Warmer sea at indoor temperature 20 °C and outdoor to	Declared coefficient of performance/Warm at indoor temperature 20 °C and outdoor te		Tj						
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit		
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-		
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-		
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-		
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-		
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COPd	N/A	-		

Heating/Colder	Heating/Colder									
Declared capacity for heating/Colder season at indoor temperature 20 °C and outdoor to	Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj									
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit			
Tj = -7°C	Pdh	N/A	kW	$Tj = -7^{\circ}C$	COPd	N/A	-			
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-			
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COPd	N/A	-			
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COPd	N/A	-			
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-			
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COPd	N/A	-			
Tj=-15°C	Pdh	N/A	kW	Tj = -15°C	COPd	N/A	-			

Bivalent temperature			Operating limit temperature				
Item	Symbol	Value	Unit	ltem	Symbol	Value	Unit
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	N/A	°C	Heating/Warmer	Tol	N/A	°C
Heating/Colder	Tbiv	N/A	°C	Heating/Colder	Tol	N/A	°C

Cycling interval capacity			Cycling interval efficiency				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	Pcycc	N/A	kW	For cooling	EERcyc	N/A	-
For heating	Pcych	N/A	kW	For heating	COPcyc	N/A	-
Degradation coefficient cooling	Cdc	0.25	-	Degradation coefficient heating	Cdh	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	ltem	Symbol	Value	Unit
Off mode (Cooling/Heating)	P <sub>OFF</sub>	6.0/6.0	W	Cooling	Q <sub>CE</sub>	293	kWh/a
Standby mode (Cooling/Heating)	P <sub>SB</sub>	6.0/6.0	W	Heating/Average	$Q_{HE}$	1297	kWh/a
Thermostat-off mode (Cooling/Heating)	P <sub>TO</sub>	3.0/15.0	W	Heating/Warmer	Q <sub>HE</sub>	N/A	kWh/a
Crankcase heater mode (Cooling/Heating)	P <sub>CK</sub>	0.0/0.0	W	Heating/Colder	Q <sub>HE</sub>	N/A	kWh/a

Capacity control	Other items				
Item	Y/N	ltem	Symbol	Value	Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L <sub>WA</sub>	47.0/63.0	dB(A)
Staged	No	Global warming potential	GWP	675	kgCO <sub>2</sub> eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	1050/1710	m³/h

	FUJITSU GENERAL LIMITED
Contact details for obtaining more information	3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan

V20121214