## Information sheet (Lot.10)

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011. Information to identify the model(s) to which the information relates to:

		AIR CONDITIONER
TYPE	:	SINGLE SPLIT
		WALL MOUNTED
Indoor unit(s)	:	ASYG14KMTB
Outdoor unit	:	AOYG14KMTA
BRAND	:	FUJITSU

			N/A = Not Applicable		
Function					
Cooling	Yes	Average	Yes		
Heating	Yes	Warmer	Yes		
		Colder	No		

Design load			Seasonal efficiency				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Cooling	Pdesignc	4.2	kW	Cooling	SEER	6.90	-
Heating/Average	Pdesignh	4.0	kW	Heating/Average	SCOP/A	4.10	-
Heating/Warmer	Pdesignh	2.1	kW	Heating/Warmer	SCOP/W	5.62	-
Heating/Colder	Pdesignh	N/A	kW	Heating/Colder	SCOP/C	N/A	-

Cooling								
Declared capacity for cooling, at indoor temperature 27 (19) °C and outdoor temperature Tj				Declared energy efficiency ratio, at indoor temperature 27 (19) °C and outdoor temperature Tj				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Tj = 35°C	Pdc	4.20	kW	Tj = 35°C	EER d	3.44	-	
Tj = 30°C	Pdc	3.09	kW	Tj = 30°C	EER d	5.10	-	
Tj = 25°C	Pdc	1.99	kW	Tj = 25°C	EER d	8.75	-	
Tj = 20°C	Pdc	1.21	kW	Tj = 20°C	EERd	12.20	-	

Heating/Average									
Declared capacity for heating/Average sea at indoor temperature 20 °C and outdoor te	Declared coefficient of performance/Average at indoor temperature 20 °C and outdoor to		Tj						
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit		
Tj = -7°C	Pdh	3.54	kW	Tj = -7°C	COPd	2.45	-		
Tj = 2°C	Pdh	2.15	kW	Tj = 2°C	COPd	3.97	-		
Tj = 7°C	Pdh	1.38	kW	Tj = 7°C	COPd	5.81	-		
Tj = 12°C	Pdh	0.96	kW	Tj = 12°C	COPd	6.50	-		
Tj = bivalent temperature	Pdh	3.54	kW	Tj = bivalent temperature	COPd	2.45	-		
Tj = operating limit	Pdh	3.33	kW	Tj = operating limit	COPd	2.50	-		

Heating/Warmer								
Declared capacity for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Tj = 2°C	Pdh	2.14	kW	Tj = 2°C	COPd	3.93	-	
Tj = 7°C	Pdh	1.38	kW	Tj = 7°C	COPd	5.81	-	
Tj = 12°C	Pdh	0.96	kW	Tj = 12°C	COPd	6.54	-	
Tj = bivalent temperature	Pdh	2.14	kW	Tj = bivalent temperature	COPd	3.93	-	
Tj = operating limit	Pdh	3.33	kW	Tj = operating limit	COPd	2.50	-	

Heating/Colder								
Declared capacity for heating/Colder sea at indoor temperature 20 °C and outdoor	Declared coefficient of performance/Colder season, at indoor temperature 20 °C and outdoor temperature Tj							
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Tj = -7°C	Pdh	N/A	kW	Tj = -7°C	COPd	N/A	-	
Tj = 2°C	Pdh	N/A	kW	Tj = 2°C	COPd	N/A	-	
Tj = 7°C	Pdh	N/A	kW	Tj = 7°C	COP d	N/A	-	
Tj = 12°C	Pdh	N/A	kW	Tj = 12°C	COP d	N/A	-	
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COP d	N/A	-	
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COP d	N/A	-	
Tj=-15°C	Pdh	N/A	kW	Tj = −15°C	COP d	N/A	-	

Bivalent temperature			Operating limit temperature				
Item	Symbol	Value	Unit	ltem	Symbol	Value	Unit
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	2	°C	Heating/Warmer	Tol	-15	°C
Heating/Colder	Tbiv	N/A	°C	Heating/Colder	Tol	N/A	°C

Cycling interval capacity			Cycling interval efficiency				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
For cooling	Pcycc	N/A	kW	For cooling	EERcyc	N/A	-
For heating	Pcych	N/A	kW	For heating	COPcyc	N/A	-
Degradation coefficient cooling	Cdc	0.25	-	Degradation coefficient heating	Cdh	0.25	-

Electric power input in power modes other than 'active mode'				Annual electricity consumption			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Off mode (Cooling/Heating)	POFF	5.0/5.0	W	Cooling	Q <sub>CE</sub>	213	kWh/a
Standby mode (Cooling/Heating)	P <sub>SB</sub>	5.0/5.0	W	Heating/Average	Q <sub>HE</sub>	1367	kWh/a
Thermostat-off mode (Cooling/Heating)	P <sub>TO</sub>	1.0/12.0	W	Heating/Warmer	Q <sub>HE</sub>	533	kWh/a
Crankcase heater mode (Cooling/Heating)	Р <sub>ск</sub>	0.0/0.0	W	Heating/Colder	Q <sub>HE</sub>	N/A	kWh/a

Capacity control	Other items				
ltem	Y/N	Item	Symbol	Value	Unit
Fixed	No	Sound power level (Indoor/Outdoor)	L <sub>WA</sub>	57.0/65.0	dB(A)
Staged	No	Global warming potential	GWP	675	kgCO2eq.
Variable	Yes	Rated air flow (Indoor/Outdoor)	-	770/1850	m³/h

	FUJITSU GENERAL LIMITED
Contact details for obtaining more information	3-3-17, Suenaga, Takatsu-ku, Kawasaki, 213-8502, Japan

V20121214